# **CITY OF COQUITLAM - DOGWOOD PAVILION - DUST EXTRACTION REPLACEMENT** 1655 WINSLOW AVENUE, COQUITLAM, BC







IVER TANK					
MANUFACTURER	MODEL	TANK SIZE	DIMENSIONS	NOTES	
		(GALLONS)	(DIAxL) (IN)		
INGERSOLL RAND	38020012	30	16x38	ALL	
VERTICAL TANK					
STEEL TANK					
3 COMPLETED WITH DRAIN PAN BELOW					
	VER TANK MANUFACTURER INGERSOLL RAND VERTICAL TANK STEEL TANK COMPLETED WITH DRAIN PA	VER TANK MANUFACTURER MODEL INGERSOLL RAND 38020012 VERTICAL TANK STEEL TANK COMPLETED WITH DRAIN PAN BELOW	VER TANK MANUFACTURER MODEL TANK SIZE (GALLONS) INGERSOLL RAND 38020012 30 VERTICAL TANK STEEL TANK COMPLETED WITH DRAIN PAN BELOW	VER TANK         MANUFACTURER       MODEL       TANK SIZE       DIMENSIONS         (GALLONS)       (DIAXL) (IN)         INGERSOLL RAND       38020012       30       16x38         VERTICAL TANK       STEEL TANK         COMPLETED WITH DRAIN PAN BELOW	

DUST COL	LECTOR						
EQUIPMENT	LOCATION	MANUFACTURER	MODEL	AIRFLOW	E.S.P.	POWER	NOTES
TAG				(CFM)	(IN. WG)	(HP)	
DC-1	STORAGE	DONALDSON TORIT	UMA 250	2500	9	10	ALL
NOTES:	OTES:						
1	1 FILTER, STARTER, CATRIDGE, AND BARRELS PACKAGE TO BE PROVIDER BY SUPPLIER						
2	NEOPRENE GASKET BELOW UNIT IS TO BE INSTALLED						

AUTOMAT	FIC BLAST GATE					
EQUIPMENT	MANUFACTURER	MODEL	SIZE	OVERALL DIMENSIONS	VOLT/PH./Hz	NOTES
TAG				(IN)		
ABG-1	NORDFAB	NFES 3245	3	16x6.38x5.50	120/1/60	ALL
ABG-2	NORDFAB	NFES 3245	4	16x6.30x5.50	120/1/60	ALL
ABG-3	NORDFAB	NFES 3245	5	17.5x7.50x5.25	120/1/60	ALL
ABG-4	NORDFAB	NFES 3245	6	20.5x8.66x5.25	120/2/60	ALL
NOTES:						
1	GALVANIZED STEEL GATES					
2	14 GAUGE					
3	COMPLETED PACKAGE CONT	ROL PROVIDED BY SUPE	I IFR.			

AIR COMF	RESSOR								
EQUIPMENT	MANUFACTURER	MODEL	MAX. PRESS.	TANK CAPACITY	POWER	VOLT/PH./Hz	DIMENSIONS	WEIGHT	NOTES
TAG			(PSI)	(GALLONS)	(HP)		(LxWxH) (IN)	(LBS)	
AC-1	SWAN	DA-103	115	10	3.0	120/1/60	28x16x27	99	ALL
NOTES:									
1	DRAIN PAN BELOW THE	DRAIN PAN BELOW THE COMPRESSOR IS TO BE PROVIDED							

#### APPROXIMATE SCOPE OF WORK AREA

# MECHANICAL DRAWING LIST

DRAWINGS NO.	DESCRIPTION	SCALE
M0.00	COVER PAGE	N.T.S.
M1.00	DEMOLITION PLAN	AS NOTED
M1.01	RENOVATION PLAN	AS NOTED
M2.00	MECHANICAL SPECIFICATIONS	N.T.S.

# MECHANICAL GENERAL NOTES

- THE MECHANICAL SYSTEM SHALL CONSIST OF ALL WORK SHOWN ON THE DRAWINGS, DIAGRAMS, SCHEMATICS AND AS DESCRIBED IN THE SPECIFICATIONS.
- THE MECHANICAL PLANS ARE DIAGRAMMATIC IN NATURE AND DO NOT ATTEMPT TO SHOW ALL REQUIRED OFFSETS. REFER TO ARCHITECTURAL AND STRUCTURAL DRAWINGS FOR ADDITIONAL CONSTRUCTION DETAILS.
- COORDINATE THE DRAWINGS WITH THE SPECIFICATIONS AND IN CASES WHERE CONFLICTS OCCUR THE MOST STRINGENT REQUIREMENT SHALL APPLY.
- CONTRACTOR TO COORDINATE ALL MECHANICAL WORK WITH THAT OF OTHER TRADES TO ENSURE PROPER AND ADEQUATE INTERFACE WITH THE WORK OUTLINED FOR THIS PROJECT.
- CONTRACTOR TO PROVIDE HORIZONTAL AND VERTICAL CLEARANCE REQUIREMENTS AS PER CEC (CANADIAN ELECTRICAL CODE) FOR ALL INSTALLED EQUIPMENT. OFFSET MECHANICAL WORK AS REQUIRED TO MEET THIS REQUIREMENT. MECHANICAL EQUIPMENT SHALL NOT BE USED FOR TEMPORARY HEATING DURING THE
- CONSTRUCTION PROCESS. A WRITTEN LETTER FROM THE OWNER IS REQUIRED TO DO SO. ALL DUCTWORK SIZES ARE SHOWN AS INSIDE CLEAR. ADD APPROPRIATE DIMENSION FOR
- INSULATION OR DUCT LINER TO OBTAIN "TOTAL DUCT SIZE".
- CONTRACTOR TO ALLOW AND PROVIDE FOR METAL DUCTWORK TRANSITIONS BETWEEN ALL EQUIPMENT AND DUCT CONNECTIONS.
- COORDINATE EXACT LOCATIONS OF ALL ROOM THERMOSTATS AND/OR ROOM TEMPERATURE SENSORS WITH THE DESIGN ARCHITECT BEFORE FINAL INSTALLATION.

MECHANICAL RENOVATION NOTES

- THE CONTRACTOR SHALL BE REQUIRED TO ATTEND A PRE-INVESTIGATION WALK THROUGH TO ENSURE A PROPER UNDERSTANDING OF THE MECHANICAL SCOPE OF WORK
- CONTRACTOR IS RESPONSIBLE FOR REVIEWING AND VERIFYING ACTUAL ON-SITE CONDITIONS AND EQUIPMENT LOCATIONS PRIOR TO ANY AND ALL DEMOLITION WORK AND/OR EQUIPMENT REMOVAL.
- CONTRACTOR TO INCLUDE AS A PART OF THE PROPOSAL ALL COSTS ASSOCIATED WITH CUTTING AND PATCHING THAT IS REQUIRED TO INSTALL ALL NEW MECHANICAL SYSTEMS AS REQUIRED TO MEET THE SITE CONDITIONS AS SHOWN ON THE DRAWINGS. PATCHING SHALL MEET THE AESTHETIC CONDITIONS WHICH WAS THE CONDITION PRIOR TO ANY CUTTING BEING PREFORMED.
- CONTRACTOR TO PROPERLY SEAL AND REPAIR ANY AND ALL DAMAGE THAT IS A RESULT OF REMOVAL OR DEMOLITION OF MECHANICAL EQUIPMENT. THIS INCLUDES BUT IS NOT LIMITED TO WALL, DOOR, CEILINGS, ETC.
- THE EXISTING FACILITIES MECHANICAL SYSTEMS SHALL REMAIN OPERATIONAL DURING THE CONSTRUCTION AND RENOVATION PERIOD. CONTRACTOR TO COORDINATE CONSTRUCTION ACTIVITIES AND PHASING WITH OWNER TO MINIMIZE DISPUTIONS TO OWNERS OPERATIONS AND ACCESS, AND TO ENSURE SAFETY OF THE USERS. PROVIDE ALL MEASURES REQUIRED TO PREVENT HAZARDS TO PEOPLE AND DAMAGE TO ITEMS REMAINING INCLUDING BUT NOT LIMITED TO DAMAGE FROM DUST AND HEAT.
- THE EXISTING DRAWINGS HAVE BEEN PREPARED, IN PART, ON THE BASIS OF INFORMATION COMPILED AND FURNISHED BY OTHERS. AS A RESULT, THE ENGINEER WILL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS WHICH HAVE BEEN INCORPORATED INTO THIS DOCUMENT.
- DURING REMOVAL OF ITEMS SO INDICATED, CAUTION SHOULD BE USED TO PREVENT DAMAGE TO ANY EQUIPMENT HAVING SALVAGE VALUE. ALL REUSABLE SALVAGED MATERIAL SHALL REMAIN THE PROPERTY OF THE OWNER AND BE RETAINED FOR THEIR INSPECTION. ONLY ITEMS AGREED BY THE OWNER SHALL BE DISPOSED OF BY THE CONTRACTOR.
- CONTRACTOR SHALL COORDINATE AND SCHEDULE WORK WITH FACILITY TO LIMIT INTERFERENCE WITH OPERATIONS.

ROOFTOP UNIT SCHEDULE

TAG		RTU-1
LOCATION		ROOF
SERVICE		WOODWORKING
MANUFACTURER		ENGINEERED AIR
MODEL		DJE20/O/R
VOLT (V/PH/CYC)		208/3/60
MCA		8.1
SUPPLY FAN		
NORMAL VOLUME (CFM)		2,000
EXTERNAL STATIC (INCH)		1.30
FAN TYPE		BELT DRIVE
FAN SPEED (RPM)		1,934
MOTOR (HP)		0.78
HEATING SECTION		
INPUT CAPACITY (MBH)		200
OUTPUT CAPACITY (MBH)		160
TURNDOWN RATIO		15:1
TEMPERATURE RISE (DEG. F)		74
FILTERS		
MAIN FILTER		MERV 8
DIMENSIONS		
L x W x H (IN)		82 x 67 x 33
WEIGHT (LBS)		1,200
NOTES		
NOTES:		
	1.	SINGLE POINT POWER CONNECTION TO UNIT
	2.	BOTTOM SUPPLY AND BOTTOM RETURN
	3.	NEW UNIT TO SIT ON EXISTING ROOF CURB

MECH	ANICAL ABBREVIATIONS
AD	AREA DRAIN
AFF	
ARCH	ARCHITECTURAL
BB DD	BASEBOARD HEATER
BDD	BOTTLE FILLER
BFP BHP	BACKFLOW PREVENTER
BMS	BUILDING MANAGEMENT SYSTEM
BT CB	
CFM	CUBIC FEET PER MINUTE
CLG	
CONN	CONNECTION
C/W	
CONT	CONNECT TO EXISTING
DB	
DCVA	DIRECT DIGITAL CONTROL
DEG	
DF	DIAMETER
DN	
DUC	DISH WASHER
DWG	DRAWING
E/A EAT	EATTAUST AIR ENTERING AIR TEMPERATURE
EF	EXHAUST FAN
ELEC	ELECTRICAL
ENT	
ESP EWT	EXTERNAL STATIC PRESSURE ENTERING WATER TEMPERATURE
EXH	EXHAUST
FA FB	FROM ABOVE FROM BELOW
FD	FLOOR DRAIN
FE FFD	FIRE EXTINGUISHER FUNNEL FLOOR DRAIN
FLA	FULL LOAD AMPS
FLR FPM	FLOOR FEET PER MINUTE
GPM	GALLONS PER MINUTE
GWB HD	GYPSUM WALL BOARD HUB DRAIN
НВ	HOSE BIBB
HP ID	HORSEPOWER INSIDE DIAMETER
INV	INVERT
JS KW	JANITOR SINK
KS	KITCHEN SINK
LV I AT	LAVATORY LEAVING AIR TEMPERATURE
LWT	LEAVING WATER TEMPERATURE
MAU MAX	MAKE-UP AIR UNIT MAXIMUM
МН	MANHOLE
MBH MD	1000 BRITISH THERMAL UNITS/HOUR MOTORIZED DAMPER
MECH	MECHANICAL
MIN NFHB	MINIMUM NON FREEZE HOSE BIB
NIC	NOT IN CONTRACT
NC NO	NOISE CRITERIA/NORMALLY CLOSED NORMALLY OPEN
NTS	NOT TO SCALE
O/A OBD	OUTDOOR AIR OPPOSED BLADE DAMPER
OED	
OD POC	
PRV	PRESSURE REDUCING VALVE
PSI R/A	POUNDS PER SQUARE INCH RETURN AIR
RF	RETURN FAN
RM RPM	REVOLUTIONS PER MINUTE
RWL	
S/A SF	SUPPLY FAN
SH	SHOWER
SK SS	STAINLESS STEEL
SP	STATIC PRESSURE
SPEC ST	STORM
T/A	
ТВ	TO BELOW
TBC	
TD	
THRU	
TSP	TOTAL STATIC PRESSURE
TYP	
VFD	
VTR	VENT THROUGH ROOF
WB	WET BULB
WC WG	WATER CLOSET WATER GAUGE
I Ŭ	-

SYINDUL S	CHEDULE
PIPING SYSTEM	S
	DOMESTIC COLD WATER (DCW)
<u> </u>	SANITARY VENT
SAN	SANITARY SEWER ABOVE GRADE
SAN	SANITARY SEWER BELOW GRADE
ST	STORM SEWER ABOVE GRADE
-xx-	DRAIN TILE
IR	IRRIGATION
G	GAS
	CONDENSATE DRAIN
— -HWR	HEATING WATER RETURN
	CHILLED WATER SUPPLY
CHWR	CHILLED WATER RETURN
	CONDENSER WATER SUPPLY
	REFRIGERANT SUCTION(GAS)
<b>— —</b> RL <b>— —</b>	REFRIGERANT LIQUID
FITTINGS AND V	ALVES
<b>→</b>	DIRECTION OF FLOW
	PIPE DROP
0	PIPE RISE
i	PIPE UNION
<del></del>	PIPE CLEAN-OUT
	PIPE CLEAN-OUT TO GRADE
	PIPE CAP-OFF
	ISOLATION VALVE
	CHECK VALVE
X	2-WAY CONTROL VALVE
	3-WAY CONTROL VALVE
<u>S</u>	
	SOLENOID VALVE RALANCING VALVE
—————————————————————————————————————	
►	PRESSURE REDUCING VALVE
₩	PRESSURE INDEPENDENT VALVE
► <u>ک</u>	STRAINER
	BACKFLOW PREVENTOR
Ċ	SEISMIC GAS SHUT-OFF VALVE
<b>X</b>	PIPE ANCHOR
—————	EXPANSION JOINT
	FLEX COUPLING
	PIPE SLEEVE
	HEATTRACING
	RAINS
Yé	OPEN DRAIN
<b>—</b>	HOSE-BIBB
٢	FLOOR DRAIN
<b>\</b>	
•	
Q J	AKEA DRAIN P-TRAP
۲×	
MECHANICAL E	QUIPMENT
∟ ਯ <sub>⊸∽</sub>	
╏╝ <sup>╶╺┈</sup> ┨ <sub>┺╾</sub>	
┓ ╻╼╾	
 ∩∎	
<b>Y</b>	
SYSTEM MONIT	ORING AND CONTROLS
Ţ	ROOM TEMPERATURE SENSOR
R(T)	REVERSE ACTING TEMPERATURE SENSOR
) E	
	CO, SENSOR
Ţ	-
	PIPE TEMPERATURE SENSOR
(P)	
<u> </u>	PRESSURE GUAGE
Ū	THERMOMETER
	FLOW SWITCH
	GAS MEIER
	WATER METER
	CONTROL WIRING
ULCTWORK	
<b>A</b>	
-	
651 <b>(</b> )	RETURN AIR DUCT DOWN
020 (0) (2)	RETURN AIR DUCT DOWN EXHAUST AIR DUCT UP
	RETURN AIR DUCT DOWN EXHAUST AIR DUCT UP EXHAUST AIR DUCT DOWN
	RETURN AIR DUCT DOWN EXHAUST AIR DUCT UP EXHAUST AIR DUCT DOWN TURNING VANES
0 [5] 0 [5] 0 [5] 1 ∭ 1	RETURN AIR DUCT DOWN EXHAUST AIR DUCT UP EXHAUST AIR DUCT DOWN TURNING VANES ACOUSTIC INSULATION BALANCING DAMPER
	RETURN AIR DUCT DOWN EXHAUST AIR DUCT UP EXHAUST AIR DUCT DOWN TURNING VANES ACOUSTIC INSULATION BALANCING DAMPER
	RETURN AIR DUCT DOWN EXHAUST AIR DUCT UP EXHAUST AIR DUCT DOWN TURNING VANES ACOUSTIC INSULATION BALANCING DAMPER BACKDRAFT DAMPER
	RETURN AIR DUCT DOWN EXHAUST AIR DUCT UP EXHAUST AIR DUCT DOWN TURNING VANES ACOUSTIC INSULATION BALANCING DAMPER BACKDRAFT DAMPER
	RETURN AIR DUCT DOWN EXHAUST AIR DUCT UP EXHAUST AIR DUCT DOWN TURNING VANES ACOUSTIC INSULATION BALANCING DAMPER BACKDRAFT DAMPER MOTORIZED DAMPER FIRE DAMPER - VERTICAL
⊗ <b>₩</b>	RETURN AIR DUCT DOWN EXHAUST AIR DUCT UP EXHAUST AIR DUCT DOWN TURNING VANES ACOUSTIC INSULATION BALANCING DAMPER BACKDRAFT DAMPER MOTORIZED DAMPER FIRE DAMPER - VERTICAL FIRE DAMPER - HORIZONTAL
	RETURN AIR DUCT DOWN EXHAUST AIR DUCT UP EXHAUST AIR DUCT DOWN TURNING VANES ACOUSTIC INSULATION BALANCING DAMPER BACKDRAFT DAMPER MOTORIZED DAMPER FIRE DAMPER - VERTICAL FIRE DAMPER - HORIZONTAL FIRE/SMOKE DAMPER
© ♥ © ♥ <sup>©</sup>	RETURN AIR DUCT DOWN EXHAUST AIR DUCT UP EXHAUST AIR DUCT DOWN TURNING VANES ACOUSTIC INSULATION BALANCING DAMPER BACKDRAFT DAMPER MOTORIZED DAMPER FIRE DAMPER - VERTICAL FIRE DAMPER - HORIZONTAL FIRE/SMOKE DAMPER DUCT CAP-OFF

20 Vo	0 - 638 S	<b>E</b> mithe	Group
۲.۵ ۲.۵	104-684-	r вс, 5995	/6B 1E3 amegroup.ca
This dr for the only b THE CO REPOR COMM	REAL REAL AND A CONTRACTOR SHALL AWING AND A CONTRACTOR SHALL TALL ERRORS ANN MENCING THE WO	n is the prop below. This th express v LL CHECK AI D OMISSION RK.	perty of the designer to be used or page or any portion thereof shall witten permission. ND VERIFY ALL DIMENSIONS AND IS TO THE CONSULTANT PRIOR TO
THESE	DRAWINGS ARE N	IOT TO BE S	CALED.
REV. 1.	DATE 2024.08.21	DESCRIP	TION OR REVIEW
2.	2024.08.28	ISSUED F	OR RFP
CON	SULTANT:		
SEAL			
PROJ	ECT TITLE:		
D	OGW	OC	D
P	4VII 1(	DN -	- DUST
., L		- · · `TI∕	
レ) -	лкА( 	>11C	
RE	EPLAC	CEN	1ENT
DPA		cc.	
rrOJ	ECT ADDRE	52: M AVE	
CC	DQUITLAM,	BC	
V3	J 6B1		
DRAV	WN BY		JH
CHEC	CKED BY		MC
SCAI	.E		N.T.S.
DATE			AUGUST 27, 2024
DRAV	WING TITLE:		,
C	OVER	PAG	θE
-			
PRO.			
		-	



 DEMOLISH EXISTING DUST COLLECTION EQUIPMENT AND ALL ASSOCIATED COMPONENTS. EXISTING OUTDOOR LOUVER IS TO REMAIN FOR REUSE.









EXISTING ROOF CURB AND CONNECTIONS TO REMAIN FOR REUSE

- DEMOLISH EXISTING RTU





DESCRIPTION		ELOW (CEM)
	2"	100
	2"	100
CHOP SAW	5"	550
RADIAL ARM SAW	5"	550
DRILL PRESS	N/A	0
LARGE COMBINATION SANDER	<u>4" + 3"</u>	550
	<u>4''</u>	350
	<u> </u>	350
SMALL BANDSAW	3"	200
	<u>م</u> "	350
PLANER	6"	800
ROUTER TABLE	4"	350
LATHE	4"	350
,	TOTAL	5650





DETAIL NOTES FLEXIBLE DUCT TO BE FLEXHAUST FLEX-TUBE EF, FLEXMASTER TRIPLE LOCK, OR APPROVED ALTERNATE.

### COMMON WORKS

#### GENERAL

## 1.1 GENERAL SCOPE

'PROVIDE' SHALL MEAN SUPPLY AND INSTALL. 'CONSULTANT' SHALL MEAN AME GROUP CONSULTING

PROFESSIONAL ENGINEERS PROVIDE COMPLETE, FULLY TESTED AND OPERATIONAL SYSTEMS TO MEET THE REQUIREMENTS DESCRIBED HEREIN AND IN COMPLETE ACCORD WITH APPLICABLE CODES AND ORDINANCES.

CONTRACT DOCUMENTS AND DRAWINGS ARE DIAGRAMMATIC. THEY ESTABLISH SCOPE, MATERIAL AND INSTALLATION QUALITY BUT ARE NOT DETAILED INSTALLATION INSTRUCTIONS.

FOLLOW MANUFACTURERS' RECOMMENDED INSTALLATION INSTRUCTIONS, DETAILS AND PROCEDURES FOR EQUIPMENT, SUPPLEMENTED BY REQUIREMENTS OF THE CONTRACT DOCUMENTS.

BEFORE SUBMITTING PROPOSAL, VISIT AND EXAMINE THE SITE AND NOTE ALL CHARACTERISTICS AND FEATURES AFFECTING THE WORK. NO ALLOWANCES WILL BE MADE FOR ANY DIFFICULTIES ENCOUNTERED OR ANY EXPENSES INCURRED BECAUSE OF ANY CONDITIONS OF THE SITE OR ITEM EXISTING THEREON, WHICH IS VISIBLE OR KNOWN TO EXIST AT THE TIME OF PROPOSAL SUBMISSION.

CLARIFICATIONS OR REQUESTS FOR ALTERNATE MATERIALS OR EQUIPMENT MUST BE SUBMITTED IN WRITING TO THE CONSULTANT NO LATER THAN SEVEN (7) WORKING DAYS PRIOR TO THE MECHANICAL TRADES' PROPOSAL CLOSING DATE. APPROVAL OF REQUESTS SHALL ONLY BE GIVEN BY ADDENDUM.

CONSULT WITH RESPECTIVE DIVISIONS IN SETTING OUT LOCATIONS FOR DUCTWORK, EQUIPMENT, AND PIPING, SO THAT CONFLICTS ARE AVOIDED AND SYMMETRICAL EVEN SPACING IS MAINTAINED. JOINTLY WORK OUT ALL CONFLICTS ON SITE BEFORE FABRICATING OR INSTALLING ANY MATERIALS OR EQUIPMENT.

#### 1.2 CODE COMPLIANCE, PERMITS AND FEES

ALL WORK SHALL COMPLY WITH CURRENT EDITIONS OF THE NATIONAL. PROVINCIAL AND MUNICIPAL CODES. STANDARDS, ACTS AND BYLAWS AND WILL MEET THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.

OBTAIN ALL PERMITS AND PAY ALL FEES APPLICABLE TO THE SCOPE OF WORK. CONTRACTOR SHALL ARRANGE FOR INSPECTIONS OF THE WORK BY THE AUTHORITIES HAVING JURISDICTION AND SHALL PROVIDE CERTIFICATES INDICATING FINAL APPROVAL

#### **1.3 QUOTATION PRICE BREAKDOWN**

SUBMIT A PROPOSAL QUOTATION PRICE BREAKDOWN WITHIN THIRTY (30) DAYS OF PROPOSAL CLOSING AND BEFORE FIRST PROGRESS CLAIM, IN A FORMAT AGREED TO WITH THE CONSULTANT. AS A MINIMUM INCLUDE EQUIPMENT, MATERIALS AND LABOUR FOR MECHANICAL, PLUMBING, SHEET METAL, FIRE PROTECTION AND CONTROLS.

#### 1.4 SUBMITTALS

COMPLY WITH DIVISION 1 - SUBMISSION AND CLOSEOUT PROCEDURES AND IN ADDITION THE FOLLOWING:

CONTRACTOR SHALL PROVIDE AND SUBMIT TO THE CONSULTANT ASSURANCE OF PROFESSIONAL DESIGN AND COMMITMENT FOR FIELD REVIEW SCHEDULE B AND ASSURANCE OF PROFESSIONAL FIELD REVIEW AND COMPLIANCE SCHEDULE S-B FOR SEISMIC ENGINEERING.

SHOP DRAWINGS: PROVIDE SHOP DRAWINGS FOR ALL EQUIPMENT AS ELECTRONIC FILES (FILE FORMAT: .DWG .DXF, PDF, OR COMPARABLE). WHEN MANUFACTURER'S CUT SHEETS APPLY TO A PRODUCT SERIES RATHER THAN A SPECIFIC PRODUCT. THE DATA SPECIFICALLY APPLICABLE TO THE PROJECT SHALL BE HIGHLIGHTED OF CLEARLY INDICATED BY OTHER MEANS. EACH SUBMITTED PIECE OF LITERATURE AND DRAWINGS SHALL CLEARLY REFERENCE THE SPECIFICATION AND/OR DRAWING THAT THE SUBMITTAL IS TO COVER. GENERAL CATALOGS SHALL NOT BE ACCEPTED AS CUT SHEETS TO FULFILL

SUBMITTAL REQUIREMENTS. OPERATION AND MAINTENANCE MANUAL APPROVED BY, AND FINAL COPICLOSEOUT SUBMITTALS: PROVIDE A MINIMUM OF TWO (2) MECHANICAL OPERATION AND MAINTENANCE MANUALS AND ONE DIGITAL COPY.

PREPARED BY THE TAB CONTRACTOR. ES DEPOSITED WITH THE CONSULTANT A MINIMUM OF 7-DAYS BEFORE FINAL INSPECTION.

OPERATION AND MAINTENANCE MANUAL TO INCLUDE BUT NOT LIMITED TO: LAYMAN'S DESCRIPTION OF THE SYSTEMS AND ASSOCIATED CONTROLS; OPERATIONA INSTRUCTIONS, SERVICING, MAINTENANCE, OPERATION AND TROUBLE-SHOOTING INSTRUCTIONS FOR EACH ITEM OF EQUIPMENT: WARRANTIES: EQUIPMENT MANUFACTURER'S PERFORMANCE DATASHEETS INDICATING POINT OF OPERATION AS LEFT AFTER COMMISSIONING IS COMPLETE; TESTING, ADJUSTING AND BALANCING REPORTS.

RECORD DRAWINGS: CONSULTANT WILL PROVIDE 1 SET OF WHITE PRINTS AT CONTRACTORS COST TO MARK CHANGES AS WORK PROGRESSES AND AS CHANGES OCCUR. USE DIFFERENT COLOUR WATERPROOF INK FOR EACH SERVICE. DO NOT USE PENCIL OR BLACK INK. TRANSFER INFORMATION WEEKLY TO SHOW WORK AS ACTUALLY INSTALLED, DRAWINGS SHALL BE AVAILABLE

ON A WEEKLY BASIS FOR REVIEW BY THE CONSULTANT

IDENTIFY EACH DRAWING IN LOWER RIGHT HAND CORNER IN LETTERS AT LEAST 12 MM HIGH AS FOLLOWS: - "AS BUILT DRAWINGS: THIS DRAWING HAS BEEN REVISED TO SHOW MECHANICAL SYSTEMS AS INSTALLED" (SIGNATURE OF CONTRACTOR) (DATE).

SUBMIT TO CONSULTANT FOR APPROVAL AND MAKE CORRECTIONS AS DIRECTED.

SUBMIT COMPLETED CAD RECORD DRAWINGS WITH FINAL **OPERATING AND MAINTENANCE MANUALS WITHIN TWO (2)** WEEKS OF SUBSTANTIAL COMPLETION. FAILURE TO SUBMIT DRAWINGS WILL RESULT IN THE WORK BEING UNDERTAKEN BY THE OWNER AND DEDUCTED FROM THE CONTRACTOR'S HOLD BACK AMOUNT. COST TO TRANSFER **RECORD INFORMATION ONTO REPRODUCIBLE MEDIA &** AUTO-CAD DISKS ARE THIS CONTRACTOR'S RESPONSIBILITY. CONSULTANT WILL RELEASE DRAWINGS TO CONTRACTOR AFTER SIGNING A COPYRIGHT FORM. SHOULD THE CONTRACTOR CHOOSE TO UTILISE THIS CONSULTANT FOR TRANSFERRING AS BUILT INFORMATION, ALLOW \$400 / SHEET FOR ALL DRAWINGS IN THE CONSTRUCTION SET. THIS WILL COVER COSTS FOR DRAFTING TIME & PRINTING COSTS.

#### 1.5 QUALITY OF WORK

ALL WORK SHALL BE BY QUALIFIED TRADESMEN WITH VALID PROVINCIAL TRADE QUALIFICATION CERTIFICATES. SPOT CHECKS WILL BE MADE BY THE CONSULTANT. WORK WHICH DOES NOT CONFORM TO STANDARDS MAY BE REJECTED BY THE CONSULTANT. THE CONTRACTOR SHALL REDO REJECTED WORK TO THE ACCEPTED STANDARD AT NO COST TO THE OWNER.

#### 1.6 DRAWINGS AND SPECIFICATIONS

SHOULD ANY DISCREPANCY APPEAR BETWEEN DRAWINGS AND SPECIFICATIONS OBTAIN WRITTEN CLARIFICATION FROM THE CONSULTANT DURING THE PROPOSAL PERIOD WITHOUT A WRITTEN CLARIFICATION THE BETTER QUALITY AND/OR GREATER QUANTITY OF WORK OR MATERIALS SHALL BE ESTIMATED, PERFORMED AND FURNISHED WITHIN THE PROPOSED PRICE.

## 1.7 CUTTING, PATCHING AND CORING

PROVIDE HOLES AND SLEEVES, CUTTING AND FITTING REQUIRED FOR MECHANICAL WORK, RELOCATE IMPROPERLY LOCATED HOLES AND SLEEVES. ALL WORK SHALL BE COORDINATED WITH OTHER TRADES. OBTAIN WRITTEN APPROVAL FROM THE STRUCTURAL

CONSULTANT BEFORE CUTTING OR BURNING

STRUCTURAL MEMBERS PROVIDE X-RAY OF ALL REQUIRED PENETRATIONS OF THE FLOOR. X-RAY USE FOR LOCATING IN FLOOR REBAR AND CONDUIT TO BE DONE AFTER NORMAL WORKING HOURS TAKE NECESSARY PRECAUTIONS TO PROTECT COMPUTER EQUIPMENT WHEN X-RAYING FLOORS. COORDINATE WITH OWNER

1.8 INSTALLATION OF EQUIPMENT

PIPE ALL EQUIPMENT DRAINS TO BUILDING DRAINS OR SPECIFIED DRAIN METHOD EXCEPT SYSTEMS CONTAINING GLYCOL.

UNIONS AND FLANGES SHALL BE PROVIDED IN PIPING OR DUCTWORK TO PERMIT EASY REMOVAL OF EQUIPMENT. MAINTAIN PERMANENT ACCESS TO EQUIPMENT FOR MAINTENANCE.

#### 1.9 CONNECTIONS TO EXISTING SERVICES

MAINTAIN LIAISON WITH THE OWNER AND PROVIDE A MUTUALLY ACCEPTABLE SCHEDULE TO INTERRUPT REROUTE, OR CONNECT TO EXISTING BUILDING SERVICES WITH THE MINIMUM OF INTERRUPTION OF THOSE SERVICES.

#### **1.10 SELECTIVE DEMOLITION**

REMOVE FROM SITE ALL EQUIPMENT, DUCTING OR PIPING WHICH IS NO LONGER REQUIRED BECAUSE OF WORK UNDER THIS CONTRACT. EXCEPT AS OTHERWISE STATED, SALVAGEABLE MATERIALS FROM AREA OF DEMOLITION SHALL BECOME THE PROPERTY OF THE OWNER AT HIS DISCRETION.

THE INTENT IS FOR A HAZ-MAT CONTRACTOR TO REMOVE ALL ASBESTOS CONTAINING MATERIAL PRIOR TO THE PROPOSED PROJECT WORK TAKING PLACE NOTIFY THE CONSULTANT IF ASBESTOS CONTAINING MATERIAL IS SUSPECTED TO REMAIN ON SITE.

#### 1.11 EQUIPMENT AND MATERIALS

WHERE TWO OR MORE PRODUCTS OF THE SAME TYPE ARE REQUIRED, PRODUCTS SHALL BE OF THE SAME MANUFACTURER.

NOTIFY THE CONSULTANT IN WRITING TEN (10) DAYS PRIOR TO THE PROPOSAL SUBMISSION, ANY MATERIALS OR EQUIPMENT SPECIFIED WHICH IS NOT CURRENTLY AVAILABLE OR WILL NOT BE AVAILABLE FOR USE AS CALLED FOR HEREIN. FAILING THIS. THE CONTRACT WILL ASSUME THAT THE MOST EXPENSIVE ALTERNATE HAS BEEN INCLUDED IN THE PROPOSED PRICE.

APPROVED EQUIVALENTS AND/OR ALTERNATIVES TO SPECIFIED PRODUCTS SHALL BE EQUAL TO THE SPECIFIED PRODUCT IN EVERY RESPECT, OPERATE AS INTENDED, AND MEET THE SPACE, CAPACITY, AND NOISE REQUIREMENTS OUTLINED.

THE CONTRACTOR SHALL BE FULLY RESPONSIBLE FOR ANY ADDITIONAL LABOUR AND MATERIALS REQUIRED BY ANY TRADES OR OTHER CONTRACTORS TO ACCOMMODATE THE USE OF OTHER THAN SPECIFIED MATERIALS OR EQUIPMENT. THE CONTRACTOR SHALL BEAR ANY AND ALL COSTS FOR DESIGN/SYSTEM MODIFICATIONS TO ACCOMMODATE THE "ALTERNATE" EQUIPMENT. EXTRAS WILL NOT BE APPROVED TO COVER SUCH WORK.

1.12 DELIVERY, STORAGE AND HANDLING STORE MATERIALS AND EQUIPMENT IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS IN A CLEAN, DRY, WELL-VENTILATED AREA. REPLACE DEFECTIVE OR DAMAGED MATERIALS WITH NEW.

1.13 FIRESTOPPING AND SMOKE SEALS

PROVIDE FIRESTOPPING SYSTEM(S) TO PROVIDE AND MAINTAIN A FIRE RESISTANCE RATING, AS INDICATED ON DRAWINGS AND IN ACCORDANCE WITH UL, WH, ULC, CUL OR FM DESIGN DETAILS FOR ALL MECHANICAL WORK IN DIVISIONS 21, 22, 23 AND 25

FOR RENOVATION PROJECTS, IN ADDITION TO THE NECESSARY NEW PENETRATIONS. PROVIDE THE FIRESTOPPING FOR ALL EXISTING MECHANICAL ASSEMBLIES WHERE FIRESTOPPING IS DAMAGED DISCONTINUED OR ABSENT WITHIN THE CONSTRUCTION AREA.

ALL FIRESTOP SYSTEM INSTALLATIONS MUST MEET THE REQUIREMENTS OF CAN4-S115-M OR ULC S-115-M TESTED ASSEMBLIES THAT PROVIDE A FIRE RATING

A MANUFACTURER'S DIRECT REPRESENTATIVE (NOT DISTRIBUTOR OR AGENT) SHALL BE ON-SITE DURING THE INITIAL INSTALLATION OF FIRESTOP SYSTEMS TO TRAIN APPROPRIATE CONTRACTOR PERSONNEL IN CORRECT SELECTION AND INSTALLATION PROCEDURES. THIS WILL BE DONE PER MANUFACTURER'S WRITTEN RECOMMENDATIONS PUBLISHED IN THEIR LITERATURE AND DRAWING DETAILS.

#### 1.14 ACCESS DOORS

PROVIDE ACCESS DOORS FOR MAINTENANCE OR ADJUSTMENT OF ALL PARTS OF THE MECHANICAL SYSTEM

PROVIDE 300 MM X 300 MM MINIMUM SIZE FOR INSPECTION AND HAND ACCESS.

600 MM X 600 MM MINIMUM SIZE, LARGER IF INDICATED ON DRAWINGS, WHERE ENTRY IS REQUIRED AND ACCESS IS DIFFICULT.

**1.15 ESCUTCHEONS AND PLATES** PROVIDE ESCUTCHEONS AND PLATES ON ALL PIPING AND DUCTWORK PASSING THROUGH FINISHED WALLS,

# FLOORS, AND CEILINGS.

1.16 GUARANTEE / WARRANTY

FURNISH A WRITTEN GUARANTEE STATING THAT ALL WORK EXECUTED IN THIS CONTRACT WILL BE FREE FROM DEFECTIVE WORKMANSHIP AND MATERIALS FOR A PERIOD OF ONE (1) YEAR FROM THE DATE OF SUBSTANTIAL PERFORMANCE.

#### 1.17 BALANCING

THE APPROVED BALANCING AGENCIES ARE: WESTERN MECHANICAL; K.D. ENGINEERING, FLOTECH MECHANICAL BLUE COLLAR GROUP.

BALANCE EQUIPMENT AND AIR OUTLETS TO AIR QUANTITIES INDICATED ON THE DRAWINGS AND IN THIS SPECIFICATION. WHERE OUTLET QUANTITIES ARE NOT INDICATED, DIVIDE CAPACITY EQUALLY AMONG ALL OUTLETS.

SUBMIT A PDF COPY OF THE REPORT TO THE CONSULTANT WITHIN TWO (2) WEEKS AFTER SUBSTANTIAL COMPLETION FAILURE TO SUBMIT THE REPORT WITHIN THE SPECIFIED TIME WILL RESULT IN THE WORK BEING DONE BY THE OWNER AND THE COSTS DEDUCTED FROM FINAL PAYMENT.

BALANCING SHALL BE PERFORMED TO THE FOLLOWING: AIR-TERMINAL OUTLETS ±10%

AIR-CENTRAL EQUIPMENT ±5% PROVIDE A DROP TEST OF ALL FIRE DAMPERS AND A LETTER/CERTIFICATE CONFIRMING THIS WORK. COOPERATE WITH THE BAI ANCING AGENCY AND MAKE

ANY CORRECTIONS AS REQUIRED BY BALANCING AGENCY. PROVIDE BALANCING VALVES AND DAMPERS, PULLEYS, SHEAVES ETC. AS REQUESTED BY THE BALANCING AGENCY AND/OR NECESSARY TO PROPERLY ADJUST OR CORRECT THE SYSTEMS TO DESIGN FLOWS, WITHOUT ADDITIONAL COST TO OWNER.

### **1.18 COMMISSIONING AND DEMONSTRATION**

BE RESPONSIBLE FOR THE PERFORMANCE AND COMMISSIONING OF ALL EQUIPMENT SUPPLIED AND RE-USED UNDER DIVISIONS 22 AND 23. CONFIRM OPERATION AND REVIEW CONDITION OF ALL

EXISTING EQUIPMENT AND ASSOCIATED CONTROL

DEVICES IN THE RENOVATED AREA. SUBMIT REPORT NOTING ANY REMEDIAL WORK REQUIRED. AT THE CONCLUSION OF COMMISSIONING, DEMONSTRATE

THE OPERATION OF THE SYSTEMS TO THE CONSULTANT AND THEN TO THE OWNER'S OPERATING STAFF. AT THE COMPLETION OF THE COMMISSIONING, TESTING,

BALANCING AND DEMONSTRATION SUBMIT TO THE CONSULTANT A LETTER CERTIFYING THAT ALL WORK SPECIFIED UNDER THIS CONTRACT IS COMPLETE, CLEAN AND OPERATIONAL IN ACCORDANCE WITH THE SPECIFICATION AND DRAWINGS.

#### 1.19 FLASHING AND ROOF CURBS

PROVIDE CURBS. FLASH AND COUNTER FLASH AS REQUIRED WHERE MECHANICAL EQUIPMENT PASSES THROUGH WEATHER OR WATERPROOFED WALLS, FLOORS AND ROOFS.

PROVIDE FACTORY ROOF CURBS FOR ALL ROOF MOUNTED EQUIPMENT UNLESS NOTED OTHERWISE.

1.20 SEISMIC CONTROL PROVIDE SEISMIC RESTRAINTS FOR ALL REQUIRED FOUIPMENT PIPING AND DUCTWORK IN ACCORDANCE WITH THE LATEST EDITION OF THE SEISMIC RESTRAINTS MANUAL FOR MECHANICAL SYSTEMS PRODUCED BY SMACNA, AND THE LATEST EDITION OF THE ASHRAF APPLICATION HANDBOOK CHAPTER 49, SEISMIC RESTRAINTS

THE CONTRACTOR SHALL RETAIN THE SERVICES OF A QUALIFIED PROFESSIONAL SEISMIC ENGINEER (SEISMIC ENGINEER) REGISTERED IN THE PROVINCE OF BRITISH COLUMBIA. THE SEISMIC ENGINEER SHALL DESIGN AND REVIEW THE INSTALLATION OF ALL SEISMIC RESTRAINTS AS WELL AS MECHANICAL EQUIPMENT AND MECHANICAL SYSTEM SUPPORTS. THE RESTRAINTS AND SUPPORTS SHALL BE SPECIFICALLY DESIGNED TO FASTEN TO THE STRUCTURE INDICATED IN THE CONTRACT DOCUMENTS AND INSTALLED IN THE FIELD. THE COMPLETE DESIGN FOR THESE SYSTEMS SHALL COMPLY WITH ALL APPLICABLE BUILDING CODE REQUIREMENTS.

SEISMIC ENGINEER SHALL PROVIDE AND SUBMIT TO THE OWNER'S CONSULTANT ASSURANCE OF PROFESSIONAL DESIGN AND COMMITMENT FOR FIELD REVIEW SCHEDULE B AND ASSURANCE OF PROFESSIONAL FIELD REVIEW AND COMPLIANCE SCHEDULE S-B FOR SEISMIC ENGINEERING.

SUBMIT SHOP DRAWINGS OF ALL SEISMIC RESTRAINT DETAILS PREPARED AND SEALED BY THE SEISMIC ENGINEER. PRIOR TO SUBSTANTIAL COMPLETION, THE SEISMIC ENGINEER SHALL VISIT THE SITE AND VERIFY THE SEISMIC RESTRAINT INSTALLATION AS REQUIRED TO SATISFY THE ASSURANCE OF PROFESSIONAL FIELD

REVIEW AND COMPLIANCE SCHEDULE S-B OF THE BUILDING CODE. THE CONTRACTOR SHALL OBTAIN APPROVAL FOR THE

LOCATION OF ALL RESTRAINT FIXING POINTS FROM THE STRUCTURAL ENGINEER, ON SITE, PRIOR TO INSTALLATION.

WHERE EQUIPMENT IS MOUNTED ON SPRING OR RESILIENT MOUNTS FOR VIBRATION ISOLATION IT SHALL BE THE RESPONSIBILITY OF THE MANUFACTURER OF THE MOUNT TO INCORPORATE SEISMIC RESTRAINT. PROVIDE STEEL FRAME BASES WHERE NECESSARY TO ACHIEVE THIS AND ALSO AVOID OVERTURNING. THE MANUFACTURER SHALL SUPPLY CERTIFICATES. SIGNED BY A PROFESSIONAL ENGINEER REGISTERED WITHIN THE JURISDICTION, VERIFYING THE DESIGN OF THE SEISMIC RESTRAINTS IS IN ACCORDANCE WITH THIS SECTION.

#### **1.21 VIBRATION ISOLATION**

PROVIDE NEOPRENE ISOLATORS FOR DEFLECTIONS 6MM (1/4") AND UNDER. PROVIDE EITHER NEOPRENE OR STEEL SPRING

ISOLATORS FOR DEFLECTIONS BETWEEN 6MM AND 12MM (½").

PROVIDE STEEL SPRING ISOLATORS FOR DEFLECTIONS OF 12MM (1/2") AND OVER.

PROVIDE ADJUSTABLE LIMIT STOPS FOR SPRING ISOLATION MOUNTS ON EQUIPMENT WITH OPERATING WEIGHTS SUBSTANTIALLY DIFFERENT FROM THE INSTALLED WEIGHTS

ALL SPRING ISOLATORS SHALL BE "OPEN SPRING" UNLESS OTHERWISE STATED. SEISMICALLY RATED HOUSED SPRING ISOLATORS MAY BE USED IN LIEU PROVIDED THAT THEY MEET THIS PROJECT'S REQUIREMENTS FOR SEISMIC RESTRAINT

SELECT ISOLATORS IN ACCORDANCE WITH EQUIPMENT WEIGHT DISTRIBUTION TO ALLOW FOR AN AVERAGE DEFLECTION MEETING OR EXCEEDING THE SPECIFIED DEFLECTION REQUIREMENTS AND SO THAT NO ISOLATOR HAS A DEFLECTION LESS THAN 80% OF THE STATIC DEFLECTION SPECIFIED. A MINIMUM OF 4 ISOLATORS ARE REQUIRED FOR EACH PIECE OF EQUIPMENT. UNLESS SPECIFIED OTHERWISE.

1.22 SUBSTANTIAL AND TOTAL PERFORMANCE PRIOR TO REQUESTING AN INSPECTION FOR SUBSTANTIAL PERFORMANCE, PROVIDE A COMPLETE LIST OF ITEMS,

A CERTIFICATE OF SUBSTANTIAL PERFORMANCE WILL NOT BE GRANTED UNLESS THE FOLLOWING ITEMS ARE COMPLETED AND AVAILABLE TO THE OWNER'S

WHICH ARE DEFICIENT.

CONSULTANT FINAL PLUMBING INSPECTION CERTIFICATE FROM THE AUTHORITY HAVING JURISDICTION.

SCHEDULE S-B FOR SEISMIC ENGINEERING. FINAL BACKFLOW PREVENTION TEST REPORTS FOR ALL

BACKFLOW DEVICES. FIRE STOPPING AND FIRE DAMPER TEST LETTER

DRAFT OPERATING/MAINTENANCE MANUALS HAVE BEEN SUBMITTED FOR REVIEW.

ALL MECHANICAL SYSTEMS HAVE BEEN COMMISSIONED AND ARE CAPABLE OF OPERATION WITH ALARM CONTROLS FUNCTIONAL AND AUTOMATIC CONTROLS IN OPERATION.

AIR AND WATER SYSTEMS HAVE BEEN BALANCED WITH DRAFT REPORT SUBMITTED TO THE CONSULTANT.

OPERATING AND MAINTENANCE DEMONSTRATIONS HAVE BEEN PROVIDED TO THE OWNER.

ALL PREVIOUSLY IDENTIFIED DEFICIENCIES HAVE BEEN

PRIOR TO A TOTAL PERFORMANCE INSPECTION PROVIDE

PERFORMANCE DEFICIENCIES HAVE BEEN CORRECTED

THE CONSULTANT SHALL PROVIDE ONE (1) VISITATION

AND FINAL TAB REPORTS AND O&M MANUALS HAVE BEEN

FOR THE PURPOSE OF TOTAL PERFORMANCE INSPECTION.

LISTED MANUFACTURERS ARE ACCEPTABLE FOR THEIR

PRODUCT. THE LIST DOES NOT ENDORSE THE

ABILITY TO MEET THE GENERAL DESIGN INTENT, QUALITY

ACCEPTABILITY OF ALL PRODUCTS AVAILABLE FROM THE

IT REMAINS THE RESPONSIBILITY OF THE CONTRACTOR

SPECIFIED PRODUCTS IN EVERY RESPECT. OPERATE AS

SPECIFICATIONS AND PHYSICAL DIMENSIONS OF THE

THE CONTRACTOR SHALL BE FULLY RESPONSIBLE FOR

ACCOMMODATE THE USE OF EQUIPMENT FROM THE

TO ENSURE THE PRODUCTS SUPPLIED ARE EQUAL TO THE

AND PERFORMANCE CHARACTERISTICS OF THE SPECIFIED

SUBSEQUENT VISITATIONS IF REQUIRED SHALL BE AT THE

RECORD DRAWINGS HAVE BEEN SUBMITTED.

DECLARATION IN WRITING THAT SUBSTANTIAL

CORRECTED AND ACCEPTED

EXPENSE OF THE CONTRACTOR

2.1 ACCEPTABLE MANUFACTURERS

LISTED MANUFACTURERS/SUPPLIERS.

INTENDED, AND MEET THE PERFORMANCE

ANY ADDITIONAL WORK OR MATERIALS, TO

SUBMITTED.

2. PRODUCTS

SPECIFIED PRODUCT.

# ACCEPTABLE MANUFACTURERS AND SUPPLIERS LISTED.

2.2 FIRESTOPPING AND SMOKE SEALS USE THE SAME MANUFACTURER THROUGHOUT THE PROJECT AND COMPATIBLE MATERIALS FOR RESTORATION WORK

PROVIDE FILL MATERIAL COMPONENTS FOR EACH FIRESTOPPING SYSTEM AS NEEDED. USE ONLY COMPONENTS SPECIFIED BY THE FIRESTOPPING MANUFACTURER FOR THE DESIGNATED FIRE-RESISTANCE-RATED SYSTEMS. ACCEPTABLE MANUFACTURERS: 3M, HILTI, AD

FIREBARRIER, TREMCO

#### 2.3 PIPE HANGERS AND SUPPORTS

PROVIDE HANGERS AND SUPPORTS TO SECURE EQUIPMENT IN PLACE. PREVENT VIBRATION. PROTECT AGAINST DAMAGE FROM FARTHQUAKE, MAINTAIN GRADE PROVIDE FOR EXPANSION AND CONTRACTION, AND ACCOMMODATE INSULATION.

PROVIDE GALVANIZED HANGERS AND SUPPORTS FOR ALL PIPING EXCEPT HANGERS AND SUPPORTS SHALL BE COPPER PLATED OR EPOXY COATED FOR COPPER PIPING. TOGGLE HANGERS AND/OR STRAP HANGERS SHALL NOT

BE USED FOR PIPE HANGERS. POWER ACTUATED FASTENERS AND "DROP-IN" ANCHORS SHALL NOT BE USED.

PROVIDE RING TYPE HANGERS FOR PIPING UP TO NPS 11/2 AND CLEVIS TYPE HANGERS FOR PIPING OVER NPS 11/2.

### 2.4 ACCESS DOORS

DRYWALL SURFACE: EXTRUDED ALUMINUM FRAME WITH GYPSUM BOARD INLAY AND STRUCTURAL CORNER ELEMENTS. HINGE TO BE CONCEALED 2-POINT HINGE. NON-CORRODING WITH SCREWDRIVER OPERATED CAM LATCH

TILE SURFACE: UNIVERSAL DESIGN, STAINLESS STEEL DOOR (16GA) AND STAINLESS STEEL FRAME (18GA), DOOR FLUSH TO FRAME, ROUNDED SAFETY CORNERS, CONTINUOUS CONCEALED HINGE, SCREWDRIVER OPERATED CAM LATCH, #4 SATIN STAINLESS STEEL

PLASTER WALLS AND CEILING: STEEL DOOR (14GA) AND STEEL FRAME (14GA), DOOR FLUSH TO FRAME EDGE, EXPANSION CASING BEAD AND 75 MM WIDE GALVANIZED LATH SURROUND RECESSED 18 MM TO RECEIVE PLASTER. CONTINUOUS CONCEALED HINGE SCREWDRIVER OPERATED CAM LATCH, PRIME COAT GREY PAINTED

FIRE RATED WALLS NON-COMBUSTIBLE CONSTRUCTION: UNINSULATED STEEL DOOR (16GA) AND STEEL FRAME (16GA), DOOR FLUSH TO FRAME EDGE, 25MM MOUNTING FRAME WITH MASONRY ANCHOR STRAPS, CONCEALED SELE-CLOSING HINGE, FLUSH KEY LATCH, PRIME COAT GREY PAINTED FINISH, ULC RATED 2 HOUR 'B' LABEL.

FIRE RATED WALLS COMBUSTIBLE CONSTRUCTION: INSULATED STEEL DOOR (20GA) FOR MAXIMUM 250°C RISE AFTER 30 MINUTES AND STEEL FRAME (16GA), DOOR FLUSH TO FRAME EDGE, 25MM MOUNTING FRAME WITH MASONRY ANCHOR STRAPS, CONCEALED SELF-CLOSING HINGE, FLUSH KEY LATCH, PRIME COAT GREY PAINTED FINISH, ULC RATED 1-1/2 HOUR 'B' LABEL.

FIRE RATED CEILINGS: 50MM INSULATED STEEL DOOR (16GA) AND STEEL FRAME (16GA), DOOR FLUSH TO FRAME EDGE, 25MM MOUNTING FRAME WITH MASONRY ANCHOR STRAPS, CONCEALED UPSWING SELF-CLOSING HINGE, L HANDLE LATCH, WHITE BAKED ENAMEL FINISH, SIZE 600MM

X 600MM (24" X 24") ULC RATED 2 HOUR 'B' LABEL. DUCTWORK: ULTRA LOW LEAKAGE TYPE, FLAT OVAL DESIGN, GALVANIZED STEEL FRAME (22GA), DOUBLE SKIN GALVANIZED STEEL DOOR (22 GA) WITH 25MM INSULATION FULLY ENCLOSED IN PANEL, BULB TYPE SEAL INTEGRALLY FASTENED TO DOOR. LEVER CAM LOCKS. PROVIDE STAINLESS STEEL IN LIEU OF GALVANIZED STEEL IN

STAINLESS STEEL DUCTWORK. ACCEPTABLE MANUFACTURERS: MAXAM, ACUDOR,

# MILCOR, CAN.AQUA, MIFAB, BILCO, BAUCOPLUS

#### 2.5 IDENTIFICATION

DENTIFY PIPING WITH LABELS AND FLOW ARROW PROVIDE IDENTIFICATION AT 15M (50FT) MAXIMUM INTERVALS, BEFORE AND AFTER PIPES PASSING THROUGH WALLS, AT ALL SIDES OF TEES, BEHIND ACCESS DOORS. USE BRADY B-500 VINYL CLOTH LABELS FOR NON INSULATED PIPES AND B-350 FOR INSULATED PIPES. PROVIDE 20MM (3/4") DIAMETER BRASS TAGS, SECURE TO VALVE STEMS WITH KEY CHAIN. PROVIDE A VALVE DIRECTORY AT ALL MECHANICAL ROOMS, IN THE O&M MANUALS AND A DIGITAL COPY CROSS REFERENCED WITH ANY ASSOCIATED CONTROLS NOMENCLATURE.

EACH PIECE OF EQUIPMENT SHALL BE IDENTIFIED WITH ITS EQUIPMENT SCHEDULE IDENTIFICATION, E.G. SUPPLY FAN SF-1, COOLING COIL CC-1, PUMP P-1 WITH LAMACOID PLATES HAVING 6MM (1/4") MINIMUM LETTER SIZE. ACCEPTABLE MANUFACTURERS: BRADY

#### 2.6 VIBRATION ISOLATION

NEOPRENE WASHER/BUSHING: A ONE PIECE MOI DED BRIDGE BEARING NEOPRENE WASHER/BUSHING. THE BUSHING SHALL SURROUND THE ANCHOR BOLT AND HAVE A FLAT WASHER FACE TO AVOID METAL TO METAL CONTACT. USE WASHER/BUSHING ONLY ON LIGHT-WEIGHT EQUIPMENT.

ACCEPTABLE MANUFACTURER: MASON HG HEMI GROMMET OR EQUAL

NEOPRENE PAD ISOLATORS: NEOPRENE OR NEOPRENE / STEEL / NEOPRENE PAD ISOLATORS. MINIMUM STATIC DEFLECTION 2.5 MM (0.1") OR GREATER.

ACCEPTABLE MANUFACTURER: MASON WMSW OR EQUAL RUBBER FLOOR MOUNTS: BRIDGE BEARING NEOPRENE MOUNTINGS. MINIMUM STATIC DEFLECTION OF 5MM (0.2") OR GREATER AND ALL DIRECTIONAL SEISMIC CAPABILITY. ACCEPTABLE MANUFACTURER: MASON RAA OR ND OR EQUAL

SPRING FLOOR MOUNTS: SPRING ISOLATORS BUILT INTO A DUCTILE IRON OR STEEL HOUSING TO PROVIDE ALL DIRECTIONAL SEISMIC SNUBBING. THE SNUBBER SHALL

BE ADJUSTABLE VERTICALLY AND ALLOW A MAXIMUM OF 6MM (1/4") TRAVEL IN ALL DIRECTIONS BEFORE CONTACTING THE RESILIENT SNUBBING COLLARS MOLDED NEOPRENE CUP OR 1/4" (6MM) NEOPRENE ACOUSTICAL FRICTION PAD BETWEEN THE BASEPLATE AND THE SUPPORT. SPRING DIAMETERS SHALL BE NO LESS THAN 0.8 OF THE COMPRESSED HEIGHT OF THE SPRING AT RATED LOAD. SPRINGS SHALL HAVE A MINIMUM ADDITIONAL TRAVEL TO SOLID EQUAL TO 50% OF THE RATED DEFLECTION.

ACCEPTABLE MANUFACTURER: MASON SSLFH OR EQUAL SPRING HANGERS: HANGERS SHALL CONSIST OF RIGID STEEL FRAMES CONTAINING MINIMUM 32MM (1 1/4") THICK NEOPRENE ELEMENTS AT THE TOP AND A STEEL SPRING SEATED IN A STEEL WASHER REINFORCED NEOPRENE CUP ON THE BOTTOM. PROVIDE A COMBINATION RUBBER AND STEEL REBOUND WASHER AS THE SEISMIC UPSTOP FOR SUSPENDED PIPING, DUCTWORK AND EQUIPMENT RUBBER THICKNESS SHALL BE A MINIMUM OF 6MM (1/4") COLOUR CODED SPRINGS, RUST RESISTANT, PAINTED BOX TYPE HANGERS. TO MAINTAIN STABILITY THE BOXES SHALL NOT BE ARTICULATED AS CLEVIS HANGERS NOR THE NEOPRENE ELEMENT STACKED ON TOP OF THE SPRING

ACCEPTABLE MANUFACTURER: MASON HD, HS OR EQUAL ALTERNATE VIBRATION ISOLATION ACCEPTABLE MANUFACTURERS, KORFUND, VIBRO-ACOUSTICS

#### 3. EXECUTION

3.1 PAINTING REPAIRS AND RESTORATION DO PAINTING IN ACCORDANCE WITH DIVISION 09

INTERIOR PAINTING. PRIME AND TOUCH UP MARRED FINISHED PAINTWORK TO MATCH ORIGINAL. RESTORE TO NEW CONDITION, FINISHES WHICH HAVE BEEN DAMAGED. CLEAN EXPOSED BARE METAL SURFACES SUPPLIED UNDER DIVISIONS 21, 22, 23 AND 25, APPLY AT LEAST ONE COAT OF CORROSION RESISTANT PRIMER PAINT TO ALL SUPPORTS AND EQUIPMENT FABRICATED FROM FERROUS METAL

#### 3.2 DEMONSTRATION

PROJECT

SUPPLY TOOLS, EQUIPMENT, PERSONNEL TO DEMONSTRATE AND INSTRUCT THE OPERATING, AND MAINTENANCE PERSONNEL IN OPERATING. CONTROLLING ADJUSTING TROUBLE-SHOOTING AND SERVICING OF ALL SYSTEMS AND EQUIPMENT DURING REGULAR WORK HOURS, PRIOR TO ACCEPTANCE.

#### 3.3 FIRESTOPPING AND SMOKE SEALS

THE OWNER'S CONSULTANT SHALL CONDUCT MANDATORY DESTRUCTIVE REVIEWS FOR EACH TYPE OF INSTALLATION. DESTRUCTIVE TESTING SHALL BE AT THE DISCRETION OF THE OWNER'S CONSULTANT AND AUTHORITY HAVING JURISDICTION

ALLOW FOR DESTRUCTIVE TESTING OF 5% OF FIRE STOPPING APPLICATIONS. SHOULD INSTALLATIONS NOT CONFORM TO MANUFACTURER'S LISTED ASSEMBLY. AN ADDITIONAL 25% OF INSTALLATIONS MAY BE DESTRUCTIVELY TESTED AND SHOULD THERE BE MORE FAILURES, THE CONTRACTOR WILL BE RESPONSIBLE TO REMOVE ALL FIRE STOPPING PRODUCTS AND REINSTALL PRODUCTS CORRECTLY, AT NO ADDITIONAL COST TO THE

TAG ALL PENETRATIONS AND EVERY 3 METERS OF JOINT SEAL WITH PRINTED TAGS. TAGS SHALL INDICATE PRODUCT, SYSTEM #, DATE INSTALLED, INSTALLED BY (NAME AND PHONE NUMBER OF SUBCONTRACTOR) AND RE-PENETRATED BY & DATE.

TAGS SHALL STATE: CAUTION! FIRESTOP - DO NOT REMOVE, PUNCTURE OR DISCONTINUE UNLESS PREPARED TO RE-SEAL IMMEDIATELY WITH SPECIFIED PRODUCT

COMPLY WITH MANUFACTURER'S INSTRUCTIONS FOR INSTALLATION OF THROUGH-PENETRATION JOINT MATERIALS. WHERE POSSIBLE, USE METAL SLEEVES FOR FLOOR PENETRATIONS TO PREVENT/MITIGATE THE CONSEQUENCES OF LEAKAGE OR FLOODING.

PERFORM UNDER THIS SECTION PATCHING AND REPAIRING OF FIRESTOP CAUSED BY CUTTING OR PENETRATING OF EXISTING FIRESTOP SYSTEMS ALREADY INSTALLED BY OTHER TRADES.

#### 3.4 PIPE HANGERS AND SUPPORTS

PIPE SUPPORT SPACING AND HANGER ROD DIAMETER SHALL BE:

PIPE SIZE: NPS 1/2 SPACING 1.8M (6')	ROD DIAMETER 9MM (3/8"),
PIPE SIZE: NPS 3/4 TO 1 <sup>1</sup> / <sub>2</sub> SPACING 2.4M (8')	ROD DIAMETER 9MM (3/8"),
PIPE SIZE: NPS 2 TO 2 <sup>1</sup> / <sub>2</sub> SPACING 3M (10')	ROD DIAMETER 9MM (3/8"),
PIPE SIZE: NPS 3 TO 4 SPACING 3.6M (12')	ROD DIAMETER 16MM (5/8"),

PIPE SIZE: NPS 6 TO 12 ROD DIAMETER 22MM (7/8"), SPACING 4.3M (14') 3.5 PIPE PRESSURE TESTING

ADVISE CONSULTANT OR PROJECT MANAGER 48 HOURS MINIMUM PRIOR TO PERFORMANCE OF PRESSURE TESTS. HYDROSTATIC TEST: 150% OF WORKING PRESSURE, BUT NOT LESS THAN 860 KPA (125 PSIG). MAINTAIN TEST PRESSURE WITHOUT LOSS FOR 4 HOURS MINIMUM UNLESS SPECIFIED FOR LONGER PERIOD OF TIME IN RELEVANT MECHANICAL SECTIONS.

FOR PP-R PIPING, DO NOT EXCEED 1034 KPA (150 PSI). FOR PEX PIPING, DO NOT EXCEED 690 KPA (100 PSI). PRIOR TO TESTS, ISOLATE EQUIPMENT AND OTHER PARTS WHICH ARE NOT DESIGNED TO WITHSTAND TEST PRESSURE OR MEDIA.

CONDUCT TESTS IN PRESENCE OF CONSTRUCTION MANAGER OR PROJECT MANAGER.

EXAMINE ALL JOINTS FOR LEAKS AND REMAKE ALL LEAKING JOINTS WITH NEW MATERIALS. PAY COSTS FOR REPAIRS OR REPLACEMENT, RETESTING, AND MAKING

GOOD. CONSULTANT TO DETERMINE WHETHER REPAIR OR REPLACEMENT IS APPROPRIATE INSULATE OR CONCEAL WORK ONLY AFTER APPROVAL

AND CERTIFICATION OF TESTS BY AUTHORITIES. SUBMIT COPIES OF PRESSURE TEST REPORTS FOR ALL SECTIONS OF PIPING.

#### 3.6 ACCESS DOORS

PROVIDE ALL ACCESS DOORS REQUIRED TO ACCESS WORK INSTALLED BY DIVISIONS 21, 22, 23 AND 25, BE RESPONSIBLE FOR COORDINATING LOCATIONS, CUTTING OPENING AND INSTALLING PANELS. ANY SECONDARY SUPPORTS, BLOCKING FTC, WILL BE BY THE CEILING OR WALL CONTRACTOR. ENSURE THAT EQUIPMENT IS WITHIN VIEW AND ACCESSIBLE FOR OPERATING, INSPECTING, ADJUSTING, SERVICING WITHOUT USING SPECIAL TOOLS

#### 3.7 VIBRATION ISOLATION

NEOPRENE WASHER/BUSHING: ISOLATE VARIABLE FREQUENCY DRIVE CONTROLLER USING NEOPRENE WASHER/BUSHING ISOLATORS OR SOFT GROMMETS SUCH THAT STRUCTURE BORNE NOISE TRANSMISSION TO OCCUPIED SPACE IS LESS THAN AIRBORNE NOISE TRANSMISSION.

RUBBER FLOOR MOUNTS: MOUNT IN-LINE PUMPS ON TWO (2) RUBBER FLOOR MOUNT ISOLATORS UNDER EACH SUPPORT FOOT. FOR EQUIPMENT MOUNTED ON A SLAB ON GRADE MOUNT ON RUBBER FLOOR MOUNT ISOLATORS UNLESS OTHERWISE SPECIFIED. PROVIDE PROTECTION OF THE RUBBER ELEMENT FROM CONTACT WITH OIL IN THE MECHANICAL ROOM

SPRING FLOOR MOUNTS: ISOLATE ALL FLOOR OR PIER MOUNTED EQUIPMENT ON SPRING FLOOR MOUNT ISOLATORS, UNLESS OTHERWISE SPECIFIED.

SPRING HANGERS: LOCATE ISOLATION HANGERS AS NEAR TO THE OVERHEAD SUPPORT STRUCTURE AS POSSIBLE. INSTALLATION SHALL PERMIT HANGER BOX OR ROD TO MOVE THROUGH A 30 DEGREES ARC WITHOUT METAL TO METAL CONTACT, ALL DISCHARGE DUCTWORK RUNS FOR A DISTANCE OF 15M (50') FROM THE CONNECTED EQUIPMENT SHALL BE ISOLATED FROM THE BUILDING STRUCTURE BY MEANS OF SPRING HANGERS. SPRING DEFLECTION SHALL BE A MINIMUM OF 19MM (0.75").

#### **DIVISION 23 HVAC**

#### 1. GENERAL

1.1 SYSTEM CLEANING AND CHEMICAL TREATMENT

EMPLOY SERVICES OF THE EXISTING BUILDING'S WATER TREATMENT FIRM OR IF THERE IS NOT ONE, A FIRM SPECIALIZING IN HYDRONIC SYSTEM CHEMICAL TREATMENT. THIS FIRM SHALL SUBMIT A SCHEDULE OF WORK TO BE PERFORMED, CHEMICAL TYPES AND QUANTITY TO BE USED. AT THE COMPLETION OF THE

CHEMICAL TREATMENT A REPORT SHALL BE SUBMITTED TO OUTLINE THE WORK PERFORMED AND DETAILS OF PROCEDURES TO BE USED BY THE BUILDING OPERATOR FOR CONTINUED WATER QUALITY TESTING AND CHEMICAL TREATMENT

PROVIDE TEST KITS AS REQUIRED ALONG WITH ADEQUATE CHEMICALS AND REAGENTS FOR ONE YEAR OF TESTING. APPROPRIATE TEST KITS WILL BE PROVIDED TO PROPERLY TEST EACH SYSTEM INSTALLED UNDER THIS CONTRACT.

CLEAN AND FLUSH ALL NEW HOT AND COLD CLOSED LOOP WATER SYSTEM PIPING. PROVIDE A CERTIFICATE FOR THIS WORK.

#### 1.2 GRILLES, LOUVERS AND DIFFUSERS

AIRFLOW TESTS AND SOUND LEVEL MEASUREMENT SHALL BE MADE IN ACCORDANCE WITH APPLICABLE ADC EQUIPMENT TEST CODES, ASHRAE STANDARDS AND AMCA STANDARDS.

MANUFACTURER SHALL CERTIFY CATALOGUED PERFORMANCE AND ENSURE CORRECT APPLICATION OF AIR OUTLET TYPES.

OUTSIDE LOUVERS SHALL BEAR AMCA SEAL FOR FREE AREA AND WATER PENETRATION

PROJECT CONDITIONS: REVIEW REQUIREMENTS OF OUTLETS AS TO SIZE, FINISH AND TYPE OF MOUNTING PRIOR TO SUBMITTING SHOP DRAWINGS AND SCHEDULES OF OUTLETS. POSITIONS INDICATED ARE APPROXIMATE ONLY. CHECK LOCATIONS OF OUTLETS AND MAKE NECESSARY ADJUSTMENTS IN POSITION TO CONFORM WITH ARCHITECTURAL FEATURES, SYMMETRY, AND LIGHTING ARRANGEMENT.

#### 2. PRODUCTS

2.1 DUCTWORK AND ACCESSORIES

PROVIDE DUCTWORK CONSTRUCTED, REINFORCED, SEALED, AND INSTALLED TO WITHSTAND 1-1/2 TIMES THE WORKING STATIC PRESSURE.

PROVIDE LOW PRESSURE DUCTWORK 500 PA (2" W.G.) FOR SUPPLY DUCTWORK AND PLENUMS ON SYSTEMS WITHOUT TERMINAL MIXING BOXES OR AIR VALVES, SUPPLY DUCTWORK DOWNSTREAM FROM TERMINAL MIXING BOXES OR AIR VALVES, OUTDOOR AIR DUCTWORK AND PLENUMS, RETURN AIR DUCTWORK AND PLENUMS, EXHAUST AND RELIEF AIR DUCTWORK AND PLENUMS, UNLESS NOTED OTHERWISE.

LOW PRESSURE INSULATED FLEXIBLE DUCTWORK SHALL BE EQUAL TO THERMAFLEX TYPE M-KC.

PROVIDE MEDIUM PRESSURE DUCTWORK TO 1000 PA (4"W.G.) FOR SUPPLY AIR DUCTWORK DOWNSTREAM FROM SUPPLY AIR HANDLING UNITS DISCHARGE, TO TERMINAL MIXING BOXES OR AIR VALVES, EXHAUST AND RETURN AIR DUCTWORK DOWNSTREAM OF RETURN/EXHAUST AIR VALVES TO THE RETURN/EXHAUST FANS AND DISCHARGE DUCTWORK FROM THE RETURN/EXHAUST FANS TO THE AIR HANDLING UNITS AND/OR RELIEF OPENING.

WHERE FLEXIBLE AIR DUCTS ARE USED TO CONNECT TERMINAL MIXING BOXES OR AIR VALVES TO METAL DUCTS, THE FLEXIBLE AIR DUCTS SHALL BE RATED FOR 30.5 M/S (6000 FPM) VELOCITY AND 2500 PA (10" W.G.). MAXIMUM STRETCHED LENGTH OF FLEXIBLE AIR DUCT SHALL BE 300 MM (12"). DO NOT USE FLEXIBLE DUCT TO CHANGE DIRECTION. WHERE FLEXIBLE AIR DUCTS ARE ATTACHED TO METAL INSULATED DUCT, FURNISH FLEXIBLE AIR DUCTS WITH FIBERGLASS WOOL INSULATION AND METALIZED JACKET. THERMAFLEX M-KC OR EQUAL.

#### 2.2 DUCT SEALING

DUCT SEALING LOW PRESSURE DUCTWORK 500 PA (2" W.G.) AND UNDER SHALL BE SMACNA SEAL CLASS A. SEAL ALL SUPPLY, RETURN AND EXHAUST DUCT JOINTS, LONGITUDINAL AS WELL AS TRANSVERSE JOINTS AS FOLLOWS:

SLIP JOINTS: APPLY HEAVY BRUSH-ON HIGH PRESSURE DUCT SEALANT. APPLY SECOND APPLICATION AFTER THE FIRST APPLICATION HAS COMPLETELY DRIED OUT. WHERE METAL CLEARANCE EXCEEDS 1.5 MM (1/16") USE HEAVY MASTIC TYPE SEALANT.

FLANGED JOINTS: SOFT ELASTOMER BUTYL OR EXTRUDED FORM OF SEALANT BETWEEN FLANGES FOLLOWED BY AN APPLICATION OF HEAVY BRUSH-ON HIGH PRESSURE DUCT SEALANT.

OTHER JOINTS: HEAVY MASTIC TYPE SEALANT. DUCT SEALING MEDIUM PRESSURE DUCTWORK TO 1000 PA (4"W.G.) SHALL BE THE SAME AS 500 PA DUCTWORK EXCEPT PROVIDE A COMBINATION OF WOVEN FABRICS AND SEALING COMPOUND FOLLOWED BY AN APPLICATION OF HIGH PRESSURE DUCT SEALANT.

DUCT TAPES AS A SEALING METHOD ARE NOT PERMITTED, EXCEPT ON RESIDENTIAL DUCTWORK - MINIMUM 2 WRAPS OF 2" WIDE (50MM) FOIL DUCT TAPE IS ACCEPTABLE.

DO NOT INSULATE ANY SECTION OF THE DUCTWORK UNTIL IT HAS BEEN INSPECTED AND APPROVED OF DUCT SEALANT APPLICATION, BY THE CONSULTANT.

#### 2.3 DUCT HANGERS AND SUPPORTS

HANGERS AND SUPPORTS TO SMACNA STANDARDS STRAP HANGERS: OF SAME MATERIAL AS DUCT BUT NEXT SHEET METAL THICKNESS HEAVIER THAN DUCT. MAXIMUM SIZE DUCT SUPPORTED BY STRAP HANGER: 500

HANGERS: GALVANIZED STEEL ANGLE WITH GALVANIZED

STEEL RODS TO SMACNA. TOGGLE HANGERS AND/OR STRAP HANGERS SHALL NOT BE USED.

POWER ACTUATED FASTENERS AND "DROP-IN" ANCHORS SHALL NOT BE USED.

#### 2.4 DUCT AND BREECHING INSULATION

EXPOSED RECTANGULAR DUCTS: EXTERNAL RIGID INSULATION, SERVICE TEMPERATURE 5°C TO 232°C (41°F TO 450°F), MINERAL FIBER BOARD FOR LOW AND MEDIUM TEMPERATURE APPLICATIONS, ALL SERVICE ALUMINUM FOIL-SCRIM KRAFT (FSK) VAPOUR BARRIER JACKET WITH GLASS FIBRE REINFORCEMENT. FACTORY APPLIED. DENSITY 36KG/M3 (2.25 PCF), MINIMUM RSI 0.76/25MM (R 4.3/IN)

ROUND DUCTS AND CONCEALED RECTANGULAR DUCTS: EXTERNAL FLEXIBLE INSULATION, SERVICE TEMPERATURE 5°C TO 232°C (41°F TO 450°F), GLASS FIBER OR MINERAL FIBER FLEXIBLE BLANKET FOR LOW AND MEDIUM TEMPERATURE APPLICATIONS, ALL SERVICE ALUMINUM FOIL-SCRIM KRAFT (FSK) VAPOUR BARRIER JACKET WITH GLASS FIBRE REINFORCEMENT, FACTORY APPLIED. DENSITY 12KG/M3 (0.75PCF), MINIMUM RSI 0.49/25MM (R 2.8/IN) (INSTALLED)

ACOUSTIC LINING DUCTS: INTERNAL FLEXIBLE DUCT LINER, FLEXIBLE MINERAL FIBER BLANKET, FOR LOW AND MEDIUM TEMPERATURE ACOUSTICAL APPLICATIONS, AIRSTREAM SURFACE FACED WITH A BLACK MAT BONDED TO THE FIBREGLASS SUBSTRATE, AIR VELOCITY RATING 25.4 M/S (5,000 FT/MIN). DENSITY 24KG/M3 (1.5 PCF), MINIMUM RSI 0.74/25MM (R 4.2/IN)

ACOUSTIC LINING PLENUMS: INTERNAL RIGID DUCT LINER, RIGID MINERAL FIBER BOARD, FOR LOW AND MEDIUM TEMPERATURE ACOUSTICAL APPLICATIONS, AIRSTREAM SURFACE FACED WITH A BLACK MAT BONDED TO THE FIBREGLASS SUBSTRATE, AIR VELOCITY RATING 25.4 M/S (5,000 FT/MIN). DENSITY 48KG/M3 (3 PCF), MINIMUM RSI

0.76/25MM (R 4.3/IN) BREECHING INSULATION: EXTERNAL SEMI-RIGID INSULATION, SERVICE TEMPERATURE UP TO 538°C (1000°F), GLASS FIBER OR MINERAL FIBER FLEXIBLE BLANKET FOR HIGH TEMPERATURE APPLICATIONS. DENSITY 25KG/M3 (1.6PCF), MINIMUM RSI 0.25/25MM (R 1.4/IN)

#### 2.5 DUCTWORK FINISH JACKETS

THERMOCANVAS JACKET: FIRE RATED, 170G (6 OZ) FIRE RETARDANT CANVAS JACKET FOR COVERING MECHANICAL INSULATION INDOORS, 25/50 FIRE CLASS, PLAIN WAVE COTTON, NO DYES.

UTILITY FINISH: OVER RIGID INSULATION FOR RECTANGULAR DUCTWORK AND FLEXIBLE INSULATION FOR ROUND DUCTWORK. APPLY CONTINUOUS METAL CORNER BEAD TO ALL CORNERS. ADHERE VAPOR RETARDER TAPE OVER ALL JOINTS AND BREAKS IN VAPOR RETARDER, AND AT ALL CORNERS.

ALUMINUM JACKET: 51 MIL (22 GA.) THICK STUCCO OR SMOOTH ALUMINUM JACKETING WITH LONGITUDINAL SLIP JOINTS AND 50MM (2") END LAPS WITH FACTORY APPLIED PROTECTIVE LINER ON INTERIOR SURFACE.

2.6 GRILLES, LOUVERS AND DIFFUSERS ACCEPTABLE MANUFACTURES FOR AIR TERMINALS: E.H. PRICE, TITUS, ANEMOSTAT, NAILOR.

ACCEPTABLE MANUFACTURERS FOR LOUVERS: AIROLITE, PENN, AIRSTREAM, WEST VENT, NAILOR, RUSKIN.

PROVIDE BAFFLES TO DIRECT AIR AWAY FROM WALLS, COLUMNS OR OTHER OBSTRUCTIONS WITHIN THE RADIUS OF DIFFUSER OPERATION.

PROVIDE PLASTER FRAME FOR DIFFUSERS LOCATED IN PLASTER SURFACES AND ANTI-SMUDGE FRAMES OR PLAQUES ON DIFFUSERS LOCATED IN ROUGH TEXTURED SURFACES SUCH AS ACOUSTICAL PLASTER.

PROVIDE 30 MM MARGIN FRAME ON GRILLES WITH [COUNTERSUNK SCREW HOLES] [CONCEALED FASTENING]. PROVIDE OPPOSED BLADE BALANCE DAMPER,

ACCESSIBLE FROM GRILLE FACE ON ALL GRILLES LOCATED IN DRYWALL CEILINGS OR BULKHEADS. ALL GRILLES AND DAMPERS SHALL BE ALUMINUM IN WET

AREAS (I.E. SHOWERS, AQUATIC AREAS, DISHWASHING ETC.)

IN GYMNASIUM, AQUATIC CENTRES, FRONT BLADES SHALL BE FRONT PIVOTED, WELDED IN PLACE OR SECURELY FASTENED TO BE IMMOBILE.

FABRICATE GOOSENECKS OF MINIMUM 1.3 MM (18 GA.) GALVANIZED STEEL. MOUNT ON MINIMUM 300 MM (12 IN.) HIGH CURB BASE WHERE SIZE EXCEEDS 225 MM X 225 MM (9 IN. X 9 IN).

REFER TO GRILLES AND DIFFUSER SCHEDULE FOR TYPES AND CAPACITIES.

2.7 EQUIPMENT

ALL EQUIPMENT SHALL BE CSA APPROVED FOR ITS INTENDED USE.

#### 3. EXECUTION

#### 3.1 DUCTWORK AND ACCESSORIES

FABRICATE DUCTWORK IN ACCORDANCE WITH SMACNA DUCT CONSTRUCTION STANDARDS - METAL AND FLEXIBLE, NFPA 90A STANDARD FOR THE INSTALLATION OF AIR-CONDITIONING AND VENTILATING SYSTEMS, AND NFPA 90B STANDARD FOR THE INSTALLATION OF WARM AIR HEATING AND AIR-CONDITIONING SYSTEMS

PRIOR TO FABRICATION OF DUCTWORK, CHECK ALL CEILING SPACES AND HEIGHTS AND CONFLICTS WITH OTHER TRADES.

DUCT SIZES INDICATED ARE INSIDE CLEAR DIMENSIONS FOR ACOUSTICALLY LINED OR INTERNALLY INSULATED DUCTS ALLOW FOR INSULATION THICKNESS AND MAINTAIN INTERIOR CLEAR DIMENSIONS INDICATED.

CONNECT OUTLET TERMINALS TO LOW PRESSURE DUCTS WITH 900MM (36") MAXIMUM LENGTH OF STRETCHED FLEXIBLE DUCT. HOLD IN PLACE WITH STRAP OR CLAMP. CAULK SEALED. DO NOT USE FLEXIBLE DUCT TO CHANGE DIRECTIONS.

PROVIDE A FLEXIBLE CONNECTION WHERE LOW PRESSURE DUCTS ARE CONNECTED TO FAN EQUIPMENT, TERMINAL BOXES OR ANY OTHER APPARATUS. JOINT SHALL BE SCREWED OR BOLTED FLEXIBLE GASKETED JOINT, MINIMUM 50MM (2") WIDE.

PROVIDE FIRE DAMPERS WHERE DUCTS CROSS FIRE SEPARATIONS. FIRE DAMPERS SHALL BE ULC LISTED AND "DYNAMIC"; RATED TO CLOSE UNDER AIRFLOW. REFER TO ARCHITECTURAL DRAWINGS FOR FIRE SEPARATION RATINGS AND LOCATIONS.

PROVIDE BALANCING DAMPERS WHERE INDICATED ON DRAWINGS AND AT POINTS ON LOW PRESSURE SUPPLY, RETURN AND EXHAUST DUCTS WHERE BRANCHES ARE TAKEN FROM LARGER DUCTS.

MODIFY CEILING SYSTEM WHERE REQUIRED TO ACCOMMODATE GRILLES AND DIFFUSERS.

SIZE ROUND DUCTS, INSTALLED IN PLACE OF RECTANGULAR DUCTS, FROM ASHRAE TABLE OF EQUIVALENT RECTANGULAR AND ROUND DUCTS. NO VARIATION OF DUCT CONFIGURATION OR SIZES PERMITTED EXCEPT BY PERMISSION FROM THE CONSULTANT.

EXPOSED ROUND DUCTWORK TO BE SPIRAL LOCK SEAM TYPE ONLY.

PROVIDE DUCT HANGERS AND SUPPORTS IN ACCORDANCE WITH SMACNA MANUALS.

CONFIRM THE EXISTING BASE BUILDING STANDARDS

PRIOR TO SUBMITTING PROPOSAL. DUCTWORK SHALL BE GALVANIZED STEEL UNLESS NOTED

3.2 DUCT HANGERS AND SUPPORTS

DUCT SUPPORT SHALL BE:

OTHERWISE.

UP TO 750MM DUCT SIZE: ANGLE SIZE 25X25X3 MM WITH 6MM ROD SIZE

751 TO 1050MM DUCT SIZE: ANGLE SIZE 40X40X3 MM WITH 6MM ROD SIZE

1051 TO 1500MM DUCT SIZE: ANGLE SIZE 40X40X3 MM WITH 10MM ROD SIZE

1501 TO 2100MM DUCT SIZE: ANGLE SIZE 50X50X3 MM WITH 10MM ROD SIZE

2101 TO 2400MM DUCT SIZE: ANGLE SIZE 50X50X5 MM WITH 10MM ROD SIZE 2401 AND OVER DUCT SIZE: ANGLE SIZE 50X50X6 MM WITH

10MM ROD SIZE UPPER HANGER ATTACHMENTS SHALL BE:

FOR CONCRETE: MANUFACTURED CONCRETE INSERTS. FOR STEEL JOIST: MANUFACTURED JOIST CLAMP.

FOR STEEL BEAMS: MANUFACTURED BEAM CLAMPS.

# 3.3 DUCT AND PLENUM INSULATION

INSTALL ALL DUCTWORK INSULATION TO THE THERMAL INSULATION ASSOCIATION OF CANADA BEST PRACTICES

#### GUIDE.

3.4 GRILLES, LOUVERS AND DIFFUSERS PAINT DUCTWORK VISIBLE BEHIND AIR OUTLETS MATTE BLACK.

ALL AIR OUTLETS MOUNTED IN A T-BAR CEILING SHALL BE SEISMICALLY RESTRAINED BY EITHER SECURE ATTACHMENT TO SOLID DUCTWORK, WHICH IS BRACED AT THE OUTLET OR WIRE HANGERS ATTACHED TO STRUCTURE. WIRE HANGERS SHALL BE A MINIMUM OF

TWO (2) PER OUTLET AND ONE PER 1200 MM LENGTH. AIR OUTLETS OTHER THAN T-BAR MOUNTING MUST BE SECURELY ATTACHED TO THE BUILDING ELEMENTS. **DIVISION 25 INTEGRATED AUTOMATION** 

1. GENERAL

1.1 SECTION SCOPE

PROVIDE A COMPLETE SYSTEM OF AUTOMATIC CONTROLS TO MATCH THE BASE BUILDING STANDARD WITH REGARD TO CONTROL DEVICES, COMPONENTS, WIRING AND MATERIALS. ALL CONTROL WORK ASSOCIATED WITH THE WORK OF DIVISIONS 22 AND 23.

#### 1.2 RELATED REQUIREMENTS

THIS SECTION OF THE SPECIFICATION FORMS PART OF THE CONTRACT DOCUMENTS AND IS TO BE READ, INTERPRETED AND COORDINATED WITH ALL OTHER PARTS. FOR GENERAL CONDITIONS REFER TO HEATING, VENTILATION AND AIR CONDITIONING (HVAC) SECTION.

#### 1.3 CODE COMPLIANCE

ALL WORK SHALL COMPLY WITH CURRENT EDITIONS OF THE NATIONAL, PROVINCIAL AND MUNICIPAL CODES, STANDARDS, ACTS AND BYLAWS AND WILL MEET THE REQUIREMENTS OF THE AUTHORITY HAVING JURISDICTION.

#### 1.4 ACCEPTABLE CONTRACTORS

ALL CONTROLS WORK IS TO BE DONE BY THE BASE BUILDING CONTRACTOR(FILL IN NAME).

#### 1.5 EXAMINATION OF EXISTING SYSTEM

THIS PROJECT INVOLVES RENOVATION TO AN EXISTING CONTROL SYSTEM. THE CONTRACTOR SHALL INSPECT THE SYSTEM PRIOR TO PROPOSAL SUBMISSION AND INCLUDE IN HIS PROPOSAL ALL CONTROL COMPONENTS REQUIRED TO PROVIDE A FULLY OPERATIONAL SYSTEM INCLUDING REPLACEMENT OF EXISTING DEFECTIVE COMPONENTS WHERE NOTED IN THE PROJECT DOCUMENTS.

#### 1.6 DESIGN REQUIREMENTS

DESIGN AND PROVIDE CONDUIT AND WIRING LINKING ELEMENTS OF SYSTEM TO THE EXISTING BUILDING ENERGY MONITORING AND CONTROL SYSTEM EMCS.

SUPPLY SUFFICIENT PROGRAMMABLE CONTROLLERS OF TYPES TO MEET PROJECT REQUIREMENTS. QUANTITY AND POINTS CONTENTS AS REVIEWED BY CONSULTANT PRIOR TO INSTALLATION.

PROVIDE UTILITY POWER TO EMCS AS INDICATED. RETAIN THE SERVICES OF A QUALIFIED ELECTRICIAN TO PROVIDE POWER AND DATA CABLING TO EACH BUILDING AUTOMATION SYSTEM (BMS) CONTROL PANEL. POWER WIRING AND CONDUIT AS WELL AS DATA CABLING AND CONDUIT SHALL COMPLY WITH THE ELECTRICAL SPECIFICATIONS FOR THIS PROJECT. REFER TO ELECTRICAL DRAWINGS FOR ELECTRICAL PANELBOARD AND COMMUNICATION ROOM LOCATIONS. MAKE ALL NECESSARY ALLOWANCES FOR BRANCH BREAKERS REQUIRED TO BMS PANELS.

2. PRODUCTS

2.1 THERMOSTATS

RELOCATE AND RECONNECT EXISTING THERMOSTATS AS SHOWN ON THE DRAWINGS.

PROVIDE NEW THERMOSTATS WHERE INDICATED OF BUILDING STANDARD TYPE. ENSURE OPERATING CHARACTERISTICS ARE COMPATIBLE WITH CONTROL COMPONENTS (I.E. DIRECT/REVERSE ACTING).

ALL THERMOSTATS TO BE WALL OR COLUMN MOUNTED [TO MATCH EXISTING BASE BUILDING MOUNTING HEIGHT] [AT 1200MM ABOVE FINISHED FLOOR] UNLESS SPECIFICALLY NOTED OTHERWISE

ALL THERMOSTATS, EXISTING AND NEW, ARE TO BE CALIBRATED PRIOR TO AIR BALANCING. CONTACT BUILDING OWNER IF AN EXISTING THERMOSTAT NEEDS REPLACING.

# 2.2 CONTROL COMPONENTS

PROVIDE CONTROL VALVES AND DAMPER ACTUATORS AS REQUIRED TO MEET THE SEQUENCE OF OPERATION AND MEET THE DESIGN INTENT. VALVES AND ACTUATORS SHALL MATCH THE BASE BUILDING STANDARD UNLESS NOTED OTHERWISE.

CONTROL VALVES FOR NEW MECHANICAL EQUIPMENT SHALL BE PROVIDED BY CONTROLS CONTRACTOR FOR INSTALLATION BY THE MECHANICAL CONTRACTOR.

WHERE EXISTING DEVICES ARE RE-USED, VERIFY OPERATION AND RE-CALIBRATE AS REQUIRED. VERIFY CORRECT OPERATION OF CONTROLLED DEVICES INCLUDING EXISTING [AIR VALVE ACTUATORS], CONTROL VALVES, ETC. WITHIN THE AREA OF RENOVATION.

CONTROL VALVES AND ACTUATORS TO BE COMPATIBLE WITH BASE BUILDING STANDARD UNLESS NOTED OTHERWISE. NEW CONTROL VALVE OPERATION TO BE COMPATIBLE WITH EXISTING.

REPORT ANY EXISTING CONTROL DEVICE WHICH NEED REPLACEMENT. REPLACEMENT WILL BE BY BUILDING MANAGEMENT OR VIA CHANGE ORDER, AT THE DISCRETION OF THE OWNER.

#### 3. EXECUTION

3.1 GENERAL

IN GENERAL ALL CONTROLS PROVIDED SHALL BE STAND ALONE CONTROLS. CONTRACTOR TO PROVIDE ALL REQUIRED CONTROL DEVICES, THERMOSTATS, WIRING, AND CONTROLLERS TO MEET DESIGN INTENT.

AMEGroup
200 - 638 Smithe St
Vancouver BC, V6B 1E3
T.604-684-5995 amegroup.ca

<u>COPYRIGHT RESERVED</u> his drawing and design is the property of the designer to be used only or the project named below. This page or any portion thereof shall only be reproduced with express written permission. HE CONTRACTOR SHALL CHECK AND VERIFY ALL DIMENSIONS AND EPORT ALL ERRORS AND OMISSIONS TO THE CONSULTANT PRIOR TO COMMENCING THE WORK. HESE DRAWINGS ARE NOT TO BE SCALED.				
EV.	DATE	DESCRIPTION		
1.	2024.08.21	ISSUED FOR REVIEW		
2.	2024.08.28	ISSUED FOR RFP		

SEAL:

CONSULTANT:

# PROJECT TITLE:

DOGWOOD **PAVILION - DUST** EXTRACTION

REPLACEMENT PROJECT ADDRESS:

**1655 WINSLOW AVE** COQUITLAM, BC V3J 6B1

DRAWN BY	JH	
CHECKED BY	MC	
SCALE	N.T.S.	
DATE	AUGUST 27, 2024	
DRAWING TITLE:		

MECHANICAL **SPECIFICATIONS** 

PROJECT NO.	DRAWING NO.
025b-009-24	M2.00