



Addendum No. 2
City of Coquitlam
Tender No. 89033
Greene Street Watermain Replacement
 (Consists of 1 Page)

Issue Date: January 31, 2025

Tenderers shall note the following changes:

REVISIONS:

1. REFER to FORM OF TENDER

REMOVE: Appendix 1

REPLACE WITH: Revised – Appendix 1 – Revision No. 1

QUESTIONS AND CLARIFICATIONS:

Q1.) If 45 degree vertical bends are needed at the Como Lake Avenue tie-in because of the limited space between the IP gas main and existing watermain, how will we be paid for this item?

A1.) Refer to FORM OF TENDER: Revised – Appendix 1 – Revision No. 1, Pay Item 9.11.

Q2.) Do you require the new 35mm asphalt surface for both mainline and services?

A2.) Yes.

Q3.) What is the maximum trench width that is acceptable for the unit priced temporary asphalt?

A3.) The maximum trench width for the unit priced temporary asphalt is 1.2m.

Q4.) What is the maximum trench width that is acceptable for the unit priced permanent asphalt?

A4.) The maximum trench width for the unit priced permanent asphalt is 1.6m.

End of Addendum No. 2

Tenderers shall take into account the content of this Addendum in the preparation and submission of the Tender which will form part of the contract and shall be acknowledged on the Tender Form, Item 1.

Upon submitting a Tender, Tenderers will be deemed to have received notice of all Addenda that are posted on the City's website and deemed to have considered the information for inclusion in the Tender submitted.

Issued by:

Mark Pain
 Manager Procurement
 Email: bid@coquitlam.ca