



Addendum No. 1
City of Coquitlam
RFP No. 26-034

Electrical Maintenance and Repair
Issue Date: March 3, 2026
Total Page Count: 2

Proponents shall note the following amendments to the RFP documents:

REPLACE

R1) REPLACE

The following dates have been extended as part of an extension request. The entirety of "Key Dates" is replaced with the following:

KEY DATES

RFP Issue Date	Wednesday, February 25, 2026
Non-Mandatory Site Visit: Date Time and Location	Monday, March 9, 2026 2:00 PM (local time) LOCATION: City Hall Main Reception 3000 Guildford Way
Deadline for Questions Send questions to: bid@coquitlam.ca referencing the RFP name and number.	2:00 PM (local time) Friday, March 13, 2026
Submission Deadline	2:00 PM (local time) Wednesday, March 18, 2026

QUESTIONS AND CLARIFICATIONS

- Q1. Is it possible to get the serial number and information on the Generators being proposed for monthly maintenance? Are semi-annual and annual inspections for the generators that is part of the CSA C282 code required for this RFP.
- A1. **No, the scope of this RFP is limited to a monthly one-hour transfer test, including checking fluid levels, recording readings, and reporting findings. All preventive maintenance, service calls, and CSA C282 semi-annual and annual inspections are completed separately by the City's approved service provider.**

End of Addendum No. 1

Proponents take into account the content of this Addendum in the preparation and submission of the Proposal which will form part of the Contract and should be acknowledged on the Proposal Submission Form.

Upon submitting a Proposal, Proponents are deemed to have received all addenda that are issued and posted on the City's website and considered the information for inclusion in the Proposal Submission.

Issued by:

Chris Overes
Senior Procurement Specialist
bid@coquitlam.ca