



Addendum No. 1

City of Coquitlam

RFP No. 23-010

Alarm System Monitoring

Issue Date: January 12, 2023

Total Page Count: 2

Proponents shall note the following amendments to the RFP documents:

REVISIONS:

REPLACE

R1) REPLACE
REPLACE APPENDIX A.

REMOVE: 23-010 Appendix A -Type of Alarm, Locations and Price Sheet
**REPLACE WITH: 23-010 REVISED - Appendix A -Type of Alarm, Locations and Price Sheet -
REVISION No. 1.**

QUESTIONS AND CLARIFICATIONS

- Q1)** Are there additional partitions opening and closing on the same site?
A1) **For security reasons, further details regarding this subject will be given to the awarded Contractor.**
- Q2)** Are the elevators monitored by telephone, or by push button tied to main alarm panel?
A2) **All by phone except Maillardville Community Centre. It is tied to main panel.**
- Q3)** Is the ammonia alarm tied to the main panel or is it a separate system?
A3) **Ammonia alarm is separate from the main panel.**
- Q4)** Do staff entering a building during closed hours call the monitoring station, and provide:
- A closing time?
- A name and code?
A4) **There are two methods depending on the building:**
I. City staff have a PIN code and deactivate the alarm at the panel upon entering. They reactivate the alarm using their PIN at the panel upon leaving.
II. The alarm auto-sets nightly at a preset time. It is deactivated upon the first person swiping in using an access card. Should a person need to set the alarm, it can be activated with a double-swipe of an access card.
- Q5)** Who is the manufacturer of the alarm equipment currently being used?
A5) **Honeywell and Bosch.**

- Q6) Are you transmitting by:
- Telephone?
 - Telephone & network?
 - Telephone & cell?
 - Network only?
 - Cell only?

A6) Telephone & cellular.

- Q7) Will the current alarm company release the network and cell equipment, if applicable?

A7) Yes.

- Q8) Does the City of Coquitlam have the installer codes to the alarm panels?

A8) No.

- Q9) Can you please confirm the number of monitored systems per site (Indicate if more than 1 intrusion system)?

A9) Each location listed in the Appendix A -Type of Alarm, Locations and Price Sheet has one system only

End of Addendum No. 1

Proponents take into account the content of this Addendum in the preparation and submission of the Proposal which will form part of the Contract and should be acknowledged on the Proposal Submission Form.

Upon submitting a Proposal, Proponents are deemed to have received all addenda that are issued and posted on the City's website and considered the information for inclusion in the Proposal Submission.

Issued by:

M. Pain
Purchasing Manager

bid@coquitlam.ca