



## Addendum No. 1

City of Coquitlam  
Tender 73499

### Parkway Blvd & Walton Ave Pavement Rehabilitation

Issue Date: February 17, 2023  
(Consists of 2 Pages)

Tenderers shall note the following amendments to the **CONTRACT DOCUMENT** as follows:

1. Refer to: **SUPPLEMENTARY CONTRACT SPECIFICATIONS, Section 32 12 16S, Clause 1.5**

#### **ADD: Clause 1.5.9**

“The Contractor or the Owner may request adjustment of the unit prices submitted for Asphalt Pavement if the Composite Rack Posting (CRP) varies by more than 5.0% from Tender Closing Date to the time the asphalt paving is actually performed.

The CRP is a composite of the available Rack Postings for PG 64-22 FOB Langley BC.

Requests for asphalt pavement unit price adjustment must be made prior to commencing asphalt paving. The Contractor must provide the supporting documents as required by the Contract Administrator. Payment for asphalt paving performed prior to a request for price adjustment will be made at the unit price submitted.

Unit prices will be increased or decreased as applicable using the following formula:

$$\text{Adjustment} = (\text{CRP}_{\text{work}} - \text{CRP}_{\text{tender}}) \times \text{AC}_{\text{volume}}$$

Adjustment amount in dollars per tonne the unit price is modified CRP work is the CRP at the time paving is performed CRP tender is the CRP at the Tender Closing Date AC volume is the mixture design percent asphalt content, by volume.”

## **CONTRACTOR QUESTIONS & CLARIFICATIONS**

**Q1)** The milling items in the schedule of quantities for this project state a minimum depth of 150mm. Milling items are commonly listed with a maximum depth. Does the owner expect existing asphalt to exceed 150mm? Please clarify the wording in the item.

**A1)** With regards to the milling item, the intent of this item is for the Contractor to mill 150mm down from the existing road grade across site to allow for base material and

---

**asphalt placement per the typical sections in the contract drawings. The existing asphalt is not anticipated to exceed 150mm.**

---

***End of Addendum No. 1***

Tenderers shall take into account the content of this Addendum in the preparation and submission of the Tender which will form part of the contract and should be acknowledged on the Tender form where indicated.

Upon submitting a Tender, Tenderers will be deemed to have received all addenda and considered the information for inclusion in the Tender submitted.

*Issued by:*

M. Pain  
Purchasing Manager  
Email: [bid@coquitlam.ca](mailto:bid@coquitlam.ca)